

Radon Testing 2017
Curtisville Primary Center

Room #	Serial #	Radon Results 3/20/17	Radon Retest Results 4/24/17	
			Serial #	Results
Café Office	776	1		
300 Stage	775	0.4		
300	765	1.4		
301	783	1.1		
302	781	1.1		
306	785	1.6		
309	770	1.4		
312	766	1.7		
319	782	1.2		
319-D	773	1		
317	780	0.6		
334	774	1.7		
331	764	1.1		
328	768	1		
325	779	0.5		
324	769	0.8		
324-D	784	0.9		
103	772	1		
104	777	0.8		
205	778	1.5		
205-D	767	0.4		
207	763	1.2		
202	761	1.7		
203	762	1.2		
201	771	1.2		
200	625	1.7		
208	634	2.5		
Nurse	613	3		
Nurse-D	636	2.8		
Faculty	645	1.1		
Faculty-D	641	1.7		
R001	644	1		
Princ Office	632	1.4		
Main Office	615	0.8		
Janitor	643	1.9		
Library Front	642	2		
Library Class	614	1.6		
Library Back	624	1.8		
107B	646	0.7		
100	617	0.4		
107B	635	0.6		
101	623	1.4		
106	640	0.8		
105	650	2.5		
102	612	2.5		

Radon Testing 2017
Curtisville Primary Center

R002		631		0.9				
R003		621		4.4		739		0.8
R005		660		0.7				
R004		611		0.6				
Conf Room		616		1.2				
Gym		655		0.6				
206		982		0.4				

Radon is the second cause of lung cancer, after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend taking further action when the radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. A retest was completed for readings equal to or greater than 4.0 pCi/L. If the average of the two tests was less than 4.0 pCi/L, the room meets the requirement of less than 4.0 pCi/L.

Radon Testing 2017
East Union Intermediate

Room #	Serial #	Radon Results 3/20/17	Radon Retest Results 4/24/17	
			Serial #	Results
Café Office	649	1		
Faculty	599	0.9		
Main Office	570	1		
Princ Office	569	0.9		
Guidance	580	0.5		
Guidance-D	609	0.8		
Nurse	589	0.7		
Conf Room	579	0.5		
300	639	1.1		
303	590	1.5		
304	583	1.8		
301	594	0.4		
Library	608	0.4		
Library Class	584	0.7		
305	573	1.6		
Ron Clark Off	658	0.4		
306	651	0.4		
302 Stage	648	3.7		
302 Stage-D	620	4.1	720	2.8
307	585	1.3		
308	647	1.3		
409	630	1.3		
408	638	0.6		
309	656	1.5		
407	628	2.1		
400B	657	1.3		
406	627	1.7		
400A	576	1.4		
405	618	1.9		
401	575	1		
401-D	567	0.5		
404	566	1.2		
Mechanica Room	565	1.2		
500	596	0.4		
509	606	0.7		
508	586	0.4		
501A	567	1.3		
501A-D	568	0.4		
507	610	0.4		
506	562	0.6		
502	600	0.4		
505	564	0.9		
504	607	0.4		
503 Music Rm	673	0.5		
403	DB003	0.9		

East Union Intermediate

Radon is the second cause of lung cancer, after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend taking further action when the radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. A retest was completed for readings equal to or greater than 4.0 pCi/L. If the average of the two tests was less than 4.0 pCi/L, the room meets the requirement of less than 4.0 pCi/L.

Radon Testing 2017

Middle School

Room #	Serial #	Radon Results 3/20/17	Radon Retest Results 4/24/17	
			Serial #	Results
Café Office	741	1.1		
117A Boys Lock	704	2.5		
118	733	1		
119	707	0.5		
121	667	0.4		
122	703	0.7		
112-D	688	0.6		
123	705	0.4		
114	695	0.4		
113	601	0.5		
112	602	0.5		
112-D	699	0.4		
Mechanical	697	0.4		
104	732	0.7		
111	696	0.4		
105	731	0.6		
110	687	1.1		
106	754	0.4		
107	675	0.5		
109	684	7.4	668	5.5
109-D	686	6.4		
108 Wood Shop	685	0.8		
108 Wood Shop	561	0.6		
Main Office	571	0.4		
Princ Office	709	0.8		
Cromie Office	572	0.7		
Conf Room	577	0.8		
Conf Room-D	587	0.4		
125 Office	755	0.9		
Nurse Office	676	0.7		
Nurse Back Off	677	0.4		
Nurse Room	756	0.5		
Cafeteria	582	0.9		

Radon is the second cause of lung cancer, after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend taking further action when the radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. A retest was completed for readings equal to or greater than 4.0 pCi/L. If the average of the two tests was less than 4.0 pCi/L, the room meets the requirement of less than 4.0 pCi/L.

Radon Testing 2017
High School

Room #	Serial #	Radon Results 3/20/17	Radon Retest Results 4/24/17
		Serial #	Results
Café. Office	592	0.6	
Athletic Office	593	0.4	
Girls Gym Office	683	1.6	
Trainer Office	578	1.6	
Boys Gym Office	588	3	
Boys Gym Office - D	603	3	
Coaches Office	682	0.7	
Main Office	700	0.8	
Principal Office	742	0.5	
Asst. Prince Office	738	0.5	
Asst. Prince Office - D	665	0.5	
Conf Room Office	743	0.5	
Security Office	702	0.4	
Nurse's Office	663	0.6	
Nurse's Office - D	664	0.4	
Nurse - Exam 1	674	0.4	
Nurse - Exam Lobby	708	0.8	
Nurse - Exam 2	563	0.4	
Nurse - Exam 3	680	0.5	
Nurse - Waiting	670	0.4	
Practice Room Right	758	11.2	701 2
Band Room	757	1.7	
Band Office	678	2.3	
Band Office - D	736	2.5	
Chorus Room	669	0.7	
Chorus Office	672	6.9	749 1
Practice Room Left	662	6	719 1
Stage	723	0.9	
Dan L.'s Office	759	0.9	
IT Office	706	1.6	
Library Office	751	2.1	
Library Office - D	713	1.9	
Library	745	2.8	
Library	679	2.1	
104 - Art	717	4.9	734 2.3
104 - Pottery	734	3.9	
105 - Art	744	3.2	
111 - Life Skills	737	1.4	
113 - Fam Con Sci	760	0.7	
113 - Kitchen	728	0.7	
Faculty	752	1	
Student Act Room	725	1.6	
109	694	0.9	
115	693	0.9	
110	750	0.4	

Radon Testing 2017

High School

108		689		1.4				
107		715		0.7				
Guidance		727		0.5				
Guidance - D		671		0.5				
Guidance - Sue		746		0.4				
Guidance - Tina		753		0.5				
InSchool Susp.		724		0.7				
116		730		1.1				
114		661		1.8				
122		726		0.6				
Indust. Art Office		711		0.7				
117		748		0.7				
Studio		721		1				
118		718		0.4				
Tech Ed Class		716		0.7				
Metal Shop		666		1.5				
Wood Shop Office		747		0.7				
Fitness Office		710		0.8				
Weight Room		729		2.8				
Auditorium Conf Room		691		1.3				
Auditorium Office		714		1				
106		100		1.1				
107A		962		1.5				

Radon is the second cause of lung cancer, after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend taking further action when the radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. A retest was completed for readings equal to or greater than 4.0 pCi/L. If the average of the two tests was less than 4.0 pCi/L, the room meets the requirement of less than 4.0 pCi/L.

Radon Testing 2017
Administration Bldg/Warehouse

<u>Room #</u>	<u>Serial #</u>	<u>Radon Results 3/20/17</u>	<u>Radon Retest Results 4/24/17</u>		
			<u>Serial #</u>		<u>Results</u>
Chris G. Office	159	0.6			
Garry D. Office	629	0.3			
Main Office	605	0.5			
Lori B. Office	598	0.3			
Bobbi-Ann B. Office	626	0.3			
Ginny P. Office	637	0.4			
Ginny P. Office - D	595	0.4			
Dr. LB Office	654	0.6			
Janene P. Office	653	0.5			
Conf Room	619	0.5			
Emerson A. Office	698	1.2			
Bob M. Office	722	1.6			
Break Room	712	1.7			

Radon is the second cause of lung cancer, after smoking. The U.S. Environmental Protection Agency (EPA) and the Surgeon General strongly recommend taking further action when the radon test results are 4.0 pCi/L or greater. The national average indoor radon level is about 1.3 pCi/L. A retest was completed for readings equal to or greater than 4.0 pCi/L. If the average of the two tests was less than 4.0 pCi/L, the room meets the requirement of less than 4.0 pCi/L.